

System Element (Ln #/Gen ID)	For Work On:	Start Time	From Station	End Time	Short Description / Purpose of Request	System Restrictions
L-6527	1N-627	4/10/2019 8:30	1N-Onslow	4/11/2019 15:00	C Inspection 1N-627	
L-7009	L7009 outage	4/9/2019 7:00	120H-Brushy Hill	4/12/2019 0:00	L7009 outage for structure relocations	40MW South Shore generation minimum. Generation Requirements. L6002 must be closed through from 90H to 99W
L-8004	L8004 Outage	4/12/2019 6:00	79N-Hopewell	4/12/2019 19:00	L8004 outage to complete OPGW repairs	Hastings From 600MW /725, L7011+L7012 500 /600, Mainland at Hastings 570 /680, Generation restrictions apply
L-6507	79N-P6507	4/15/2019 0:00	50N-Trenton	4/15/2019 0:00	C Inspection 79N-P6507	
L-6507	79N-CT606	4/15/2019 0:00	50N-Trenton	4/15/2019 0:00	C Inspection 79N-CT606	
L-6508	79N-P6508	4/15/2019 0:00	50N-Trenton	4/15/2019 0:00	C Inspection 79N-P6508	
L-6508	79N-CT601	4/15/2019 0:00	50N-Trenton	4/15/2019 0:00	C Inspection 79N-CT601	
L-6536	74N-P6536	4/15/2019 0:00	74N-Springhill	4/15/2019 0:00	C Inspection 74N-P6536	
L-6011	17N-610	4/16/2019 9:30	120H-Brushy Hill	4/16/2019 15:00	L7N-610 Annual Mtce	
L-6507	79N-606	4/15/2019 0:00	50N-Trenton	4/18/2019 0:00	C Inspection 79N-606	
L-6508	79N-601	4/15/2019 0:00	50N-Trenton	4/18/2019 0:00	C Inspection 79N-601	
L-6040	L-6040	4/1/2019 0:00	91H-Tufts Cove	4/22/2019 0:00	Spider Lake Transmission	
L-6040	132H	4/1/2019 6:00	91H-Tufts Cove	4/22/2019 0:00	L-6040 TO EXTEND LINE IN NEW 132H SUBSTATION	
L-6517	A & B line protection	4/10/2019 0:00	2C-Port Hastings	4/30/2019 0:00	upgrade the line protection	
L-8002	L8002	3/19/2018 0:00	67N-Onslow	4/30/2019 0:00	replacement of line protection.	Onslow South 700 /875 Flow into Metro 520/525, Onslow Import 1050/1125
L-6548	L-6548 A & B Protection Systems	4/8/2019 0:00	2C-Port Hastings	5/1/2019 0:00	Port Hastings - 2C Bulk Power System Upgrades project	
L-7014	101S-P7014	5/1/2019 0:00	88S - Ligan	5/1/2019 0:00	C Inspection 101S-P7014	Generation restrictions apply, SPS levels adjusted,
L-7005	67N-L7005	5/1/2019 0:00	67N-Onslow	5/3/2019 0:00	NPPC Testing 67N-L7005	Cape Breton Export 850/1000, Onslow Import 1050/1150, SPS arming levels reduced. Mainland at Hastings 340/420
L-7005	3C-L7005	5/1/2019 0:00	67N-Onslow	5/3/2019 0:00	NPPC Testing 3C-L7005	Cape Breton Export 850/1000, Onslow Import 1050/1150, SPS arming levels reduced. Mainland at Hastings 340/420
L-7012	3C-L7012	5/1/2019 0:00	3C-Port Hastings	5/3/2019 0:00	NPPC Testing 3C-L7012	End X at East Bay incl PA1 - 735/850 MW, Onslow Import 975/1150. Generation restrictions apply, lower SPS arming limits.
L-7012	88S-L7012	5/1/2019 0:00	3C-Port Hastings	5/3/2019 0:00	NPPC Testing 88S-L7012	End X at East Bay incl PA1 - 735/850 MW, Onslow Import 975/1150. Generation restrictions apply, lower SPS arming limits.
L-7018	67N-L7018	5/1/2019 0:00	67N-Onslow	5/3/2019 0:00	NPPC Testing 67N-L7018	Onslow 740/900, Increased MDRR correction by 50 Mvar
L-8001	67N-L8001	5/1/2019 0:00	67N-Onslow	5/3/2019 0:00	NPPC Testing 67N-L8001	
L-8002	67N-L8002	5/1/2019 0:00	67N-Onslow	5/3/2019 0:00	NPPC Testing 67N-L8002	
L-7003	L7003 Outage	4/29/2019 6:30	67N-Onslow	5/10/2019 18:00	L7003 outage for structure and insulator replacements.	Onslow South 700 /875 Flow into Metro 520/525, Onslow Import 1050/1125 CBX 850/1000, Onslow Import 1050/1150, lower SPS arming levels
L-8002	L-8002	5/13/2019 0:00	67N-Onslow	5/14/2019 0:00	NPPC Testing 103H-345 BBU	Onslow South 700 /875 Flow into Metro 520/525, Onslow Import 1050/1125
L-8004	79N-P8004	6/1/2019 0:00	79N-Hopewell	6/1/2019 0:00	C Inspection 79N-P8004	Hastings From 600MW /725, L7011+L7012 500 /600, Mainland at Hastings 570 /680, Generation restrictions apply
L-8004	79N-C810	6/1/2019 0:00	79N-Hopewell	6/1/2019 0:00	C Inspection 79N-C810	Hastings From 600MW /725, L7011+L7012 500 /600, Mainland at Hastings 570 /680, Generation restrictions apply
L-8004	79N-810	6/1/2019 0:00	79N-Hopewell	6/3/2019 0:00	C Inspection 79N-810	Hastings From 600MW /725, L7011+L7012 500 /600, Mainland at Hastings 570 /680, Generation restrictions apply
L-8004	79N-881	6/1/2019 0:00	79N-Hopewell	6/3/2019 0:00	NPPC Testing 79N-881	Hastings From 600MW /725, L7011+L7012 500 /600, Mainland at Hastings 570 /680, Generation restrictions apply
L-8004	L-8004	6/5/2019 0:00	79N-Hopewell	6/7/2019 0:00	Canso Crossing tying in the new line	Hastings From 600MW /725, L7011+L7012 500 /600, Mainland at Hastings 570 /680, Generation restrictions apply
L-6548	3C B72	6/8/2019 9:30	2C-Port Hastings	6/8/2019 15:00	Isolate 3C Bus 72 for NPCC Trip Testing	
L-6543	L-6543	6/1/2019 0:00	2C-Port Hastings	6/10/2019 0:00	2C BPS PROJECT - L-6543 OUTAGE	
L-6537	L6537 Outage	6/3/2019 6:30	2C-Port Hastings	6/14/2019 18:00	L6537 Outage for structure and insulator replacements.	Generation restrictions
L-7002	L7002 Outage	5/13/2019 6:30	67N-Onslow	6/14/2019 18:00	L7002 outage for structure and insulator replacements. Includes 9 day gap.	Onslow South 670/ 850
L-6001	82V substation equipment	6/17/2019 0:00	1N-Onslow	6/28/2019 0:00	C-Maintenance	
L-6503	50N-P862	7/1/2019 0:00	1N-Onslow	7/1/2019 0:00	C Inspection 50N-P862	Onslow Import: 820 MW, Generation Restrictions apply, Lower SPS arming levels. Generation Restrictions
L-6503	1N-P6503	7/1/2019 0:00	1N-Onslow	7/1/2019 0:00	C Inspection 1N-P6503	Onslow Import: 820 MW, Generation Restrictions apply, Lower SPS arming levels. Generation Restrictions
L-6515	4C-P6515	7/1/2019 0:00	2C-Port Hastings	7/1/2019 0:00	C Inspection 4C-P6515	Onslow Import 800 to 1000 depending on local generation, Generation Restrictions apply, SPS arming levels reduced
L-8003	79N-C7803	7/1/2019 0:00	67N-Onslow	7/1/2019 0:00	C Inspection 79N-C7803	CBX 600 to 700, Generation restrictions apply, Reduce SPS arming levels
L-8004	79N-P881	7/1/2019 0:00	79N-Hopewell	7/1/2019 0:00	C Inspection 79N-P881 (B)	Hastings From 600MW /725, L7011+L7012 500 /600, Mainland at Hastings 570 /680, Generation restrictions apply
L-5527	57C-527	7/1/2019 0:00	57C-Salmon River Lak	7/3/2019 0:00	C Inspection 57C-527	
L-6503	51N-654	7/1/2019 0:00	1N-Onslow	7/3/2019 0:00	C Inspection 51N-654	Onslow Import: 820 MW, Generation Restrictions apply, Lower SPS arming levels. Generation Restrictions
L-6613	1N-862	7/1/2019 0:00	1N-Onslow	7/3/2019 0:00	NPPC Testing 1N-862	NB Tie Imports and Exports 300MW, SPS available
L-8003	79N-803	7/1/2019 0:00	67N-Onslow	7/3/2019 0:00	C Inspection 79N-803	CBX 600 to 700, Generation restrictions apply, Reduce SPS arming levels
L-8003	67N-L8003	7/1/2019 0:00	67N-Onslow	7/3/2019 0:00	NPPC Testing 67N-L8003	CBX 600 to 700, Generation restrictions apply, Reduce SPS arming levels
L-8003	79N-L8003	7/1/2019 0:00	67N-Onslow	7/3/2019 0:00	NPPC Testing 79N-L8003	CBX 600 to 700, Generation restrictions apply, Reduce SPS arming levels
L-67N-T82	67N-T82	7/1/2019 0:00	67N-Onslow	7/5/2019 0:00	C Inspection 67N-T82	ONI 750 (Group 5 SPS Cannot be Armed) Nothing on the TIE. (8002,8003,6513 must be in service)
L-6539	L6539 Outage	6/3/2019 0:00	25-Victoria Junction	7/5/2019 0:00	L6539 Outage	Generation restriction apply, Reduce SPS arming levels
L-5027	L5027A outage	6/24/2019 6:30	9W - Tusket Hydro	7/5/2019 18:00	L5027A outage for structure and insulator replacements.	
L-6515	L-6515 A & B Protection Systems	7/7/2019 0:00	2C-Port Hastings	7/23/2019 0:00	Port Hastings 2C Bulk Power System Upgrades	Onslow Import 800 to 1000 depending on local generation, Generation Restrictions apply, SPS arming levels reduced
L-8003	79N-P8003	8/1/2019 0:00	67N-Onslow	8/1/2019 0:00	C Inspection 79N-P8003	CBX 600 to 700, Generation restrictions apply, Reduce SPS arming levels
L-6515	2C-640	8/1/2019 0:00	2C-Port Hastings	8/3/2019 0:00	C Inspection 2C-640	Onslow Import 800 to 1000 depending on local generation, Generation Restrictions apply, SPS arming levels reduced
L-7005	L7005 Outage	7/15/2019 0:00	67N-Onslow	8/9/2019 0:00	L7005 Outage	Cape Breton Export 850/1000, Onslow Import 1050/1150, SPS arming levels reduced. Mainland at Hastings 340/420
L-6537	L-6537 A & B Protection Systems	7/23/2019 0:00	2C-Port Hastings	8/14/2019 0:00	Port Hastings - 2C Bulk Power System Upgrades project	Generation restrictions
301NS Pole 1	Annual Maintenance	8/18/2019 8:30	301NS-Woodbine DC	8/21/2019 8:00	Pole 1 outage for annual scheduled maintenance	
301NS Pole 2	Annual Maintenance	8/21/2019 9:00	301NS-Woodbine DC	8/24/2019 10:00	Annual Maintenance on Pole 2	
L-7015	101S-P7015	9/1/2019 0:00	101S-Woodbine	9/1/2019 0:00	C Inspection 101S-P7015	
L-7015	101S-L7015	9/1/2019 0:00	101S-Woodbine	9/3/2019 0:00	NPPC Testing 101S-L7015	
L-7015	89S-L7015	9/1/2019 0:00	101S-Woodbine	9/3/2019 0:00	NPPC Testing 89S-L7015	
L-6516	L-6516 A & B Protection Systems	8/14/2019 0:00	2C-Port Hastings	9/5/2019 0:00	Port Hastings - 2C Bulk Power System Upgrades project	CBX - 830MW, Onslow Import Normal, Generation restrictions apply
L-6549	L6549 Outage	9/2/2019 0:00	5S-Glen Tosh	10/11/2019 0:00	L6549 Outage	