

System Element (Ln #/Gen ID)	For Work On:	Start Time	From Station	End Time	Short Description / Purpose of Request	System Restrictions
L-7002	L7002 Outage	6/10/2019	67N-Onslow	7/15/2019	L7002 outage for structure and insulator replacements.	Onslow South 670/ 850
L-5026	13V Substation	7/18/2019	13V-Gulch Hydro	7/18/2019	Re-energize L-5026 and 13V substation	Generation restrictions apply to local generation
L-5527	L5527B Outage	7/15/2019	57C-Salmon River Lak	7/20/2019	L5527B outage for structure and insulator replacements.	
L-6515	L-6515 A & B Protection Systems	7/7/2019	2C-Port Hastings	7/23/2019	Port Hastings 2C Bulk Power System Upgrades	Onslow Import 800 to 1000 depending on local generation, Generation Restrictions apply, SPS arming
L-6042	Steel Towers	7/22/2019	91H-Tufts Cove	7/23/2019	Steel Tower Life Extension Project.	
L-6040	Steel Towers	7/22/2019	91H-Tufts Cove	7/24/2019	Steel Tower Life Extension Project.	
L-5527	L5527A Outage	7/21/2019	57C-Salmon River Lak	7/24/2019	L5527A outage for structure and insulator replacements.	
L-6516	L6516 Outage (22C - 59C)	7/22/2019	2C-Port Hastings	7/26/2019	L6516 (22C - 59C) outage for structure and insulator replacements.	CBX - 830MW, Onslow Import Normal, Generation restrictions apply
L-8002	L8002	3/19/2018	67N-Onslow	7/30/2019	Blocking protection on L8001 (B side) for the replacement of line protection.	Onslow South 700 /875 Flow into Metro 520/525, Onslow Import 1050/1125
L-6515	Line Protection	7/15/2019	2C-Port Hastings	7/31/2019	This work is for the 2C BPS protection upgrades. Breaker 2C-640 will be isolated.	Onslow Import 800 to 1000 depending on local generation, Generation Restrictions apply, SPS arming
L-8004	79N-P8004	8/1/2019	79N-Hopewell	8/1/2019	C Inspection 79N-P8004	Hastings From 600MW /725, L7011+L7012 500 /600, Mainland at Hastings 570 /680, Generation restri
L-8003	79N-P8003	8/1/2019	67N-Onslow	8/1/2019	C Inspection 79N-P8003	CBX 600 to 700, Generation restrictions apply, Reduce SPS arming levels
L-6508	79N-P6508	8/1/2019	50N-Trenton	8/1/2019	C Inspection 79N-P6508	
L-6507	79N-P6507	8/1/2019	50N-Trenton	8/1/2019	C Inspection 79N-P6507	
L-8004	79N-CT810	8/1/2019	79N-Hopewell	8/1/2019	C Inspection 79N-CT810	Hastings From 600MW /725, L7011+L7012 500 /600, Mainland at Hastings 570 /680, Generation restri
L-6507	79N-CT606	8/1/2019	50N-Trenton	8/1/2019	C Inspection 79N-CT606	
L-6508	79N-CT601	8/1/2019	50N-Trenton	8/1/2019	C Inspection 79N-CT601	
L-6516	22C-T61	7/18/2019	2C-Port Hastings	8/2/2019	For 22C-T61 Work	CBX - 830MW, Onslow Import Normal, Generation restrictions apply
L-8004	79N-810	8/1/2019	79N-Hopewell	8/3/2019	C Inspection 79N-810	Hastings From 600MW /725, L7011+L7012 500 /600, Mainland at Hastings 570 /680, Generation restri
L-6507	79N-606	8/1/2019	50N-Trenton	8/3/2019	C Inspection 79N-606	
L-6508	79N-601	8/1/2019	50N-Trenton	8/3/2019	C Inspection 79N-601	
L-8002	67N-L8002	8/1/2019	67N-Onslow	8/3/2019	NPCC Testing 67N-L8002	Onslow South 700 /875 Flow into Metro 520/525, Onslow Import 1050/1125
L-8004	79N-881	8/1/2019	79N-Hopewell	8/3/2019	NPCC Testing 79N-881	Hastings From 600MW /725, L7011+L7012 500 /600, Mainland at Hastings 570 /680, Generation restri
L-6515	2C-640	8/1/2019	2C-Port Hastings	8/3/2019	C Inspection 2C-640	Onslow Import 800 to 1000 depending on local generation, Generation Restrictions apply, SPS arming
L-8004	L-8004	8/5/2019	79N-Hopewell	8/7/2019	Canso Crossing tying in the new line	Hastings From 600MW /725, L7011+L7012 500 /600, Mainland at Hastings 570 /680, Generation restri
L-7005	L7005 Outage	7/15/2019	67N-Onslow	8/9/2019	L7005 Outage	Cape Breton Export 850/1000, Onslow Import 1050/1150, SPS arming levels reduced. Mainland at H
L-6537	L-6537 A & B Protection Systems	7/23/2019	2C-Port Hastings	8/14/2019	2C Bulk Power System Upgrades project	Generation restrictions
301NS Pole 1	Annual Maintenance	8/19/2019	301NS-Woodbine DC	8/22/2019	Pole 1 outage for annual scheduled maintenance	
301NS Pole 2	Annual Maintenance	8/22/2019	301NS-Woodbine_DC	8/25/2019	Annual Maintenance on Pole 2 Maritime Link.	
L-6536	74N-P6536	9/1/2019	74N-Springhill	9/1/2019	C Inspection 74N-P6536	
L-7015	101S-P7015	9/1/2019	101S-Woodbine	9/1/2019	C Inspection 101S-P7015	
L-8001	67N-L8001	9/1/2019	67N-Onslow	9/3/2019	NPCC Testing 67N-L8001	
L-7018	67N-L7018	9/1/2019	67N-Onslow	9/3/2019	NPCC Testing 67N-L7018	Onslow 740/900, Increased MDRR correction by 50 Mvar
L-7005	67N-L7005	9/1/2019	67N-Onslow	9/3/2019	NPCC Testing 67N-L7005	Cape Breton Export 850/1000, Onslow Import 1050/1150, SPS arming levels reduced. Mainland at H
L-7015	101S-L7015	9/1/2019	101S-Woodbine	9/3/2019	NPCC Testing 101S-L7015	
L-7012	3C-L7012	9/1/2019	3C-Port Hastings	9/3/2019	NPCC Testing 3C-L7012	End X at East Bay - 735/850 MW, Onslow Import 975/1150. Generation restrictions apply, lower SPS ar
L-7005	3C-L7005	9/1/2019	67N-Onslow	9/3/2019	NPCC Testing 3C-L7005	Cape Breton Export 850/1000, Onslow Import 1050/1150, SPS arming levels reduced. Mainland at H
L-7015	89S-L7015	9/1/2019	101S-Woodbine	9/3/2019	NPCC Testing 89S-L7015	
L-7012	88S-L7012	9/1/2019	3C-Port Hastings	9/3/2019	NPCC Testing 88S-L7012	End X at East Bay incl PA1 - 735/850 MW, Onslow Import 975/1150. Generation restrictions apply, low
L-6516	L-6516 A & B Protection Systems	8/14/2019	2C-Port Hastings	9/5/2019	Port Hastings - 2C Bulk Power System Upgrades project	CBX - 830MW, Onslow Import Normal, Generation restrictions apply
L-8002	L-8002	9/13/2019	67N-Onslow	9/14/2019	NPCC Testing 103H-345 BBU	Onslow South 700 /875 Flow into Metro 520/525, Onslow Import 1050/1125
L-6548	3C B72	9/16/2019	2C-Port Hastings	9/16/2019	isolate 3C Bus 72 for NPCC Trip Testing	
L-6536 (Remote H/O)	74N-636	9/3/2019	74N-Springhill	9/24/2019	74N-636 breaker replacement	
L-6549	L6549 Outage	9/2/2019	55-Glen Tosh	10/11/2019	L6549 Outage	